



R.17-09-020 WORKING GROUPS

EFC Value of Storage Resources



Background

- D.14-06-050 adopted a QC & EFC methodology for storage
 - QC=MW at which resource can discharge for 4 hrs= $P_{max}RA$
 - All EFC values based on currently-adopted definition of flexibility (per D.13-06-024): “ability to ramp and sustain output over 3 hours”
 - EFC incorporates dispatchable charging, but QC does not; thus, frequently, $EFC > QC$
 - EFC for bi-directional storage was previously capped at the NQC; D.14-06-050 modified this, capping EFC at greater of NQC and $(NQC - P_{min}RA)$




EFC of Bidirectional Storage

- P_{maxRA} = QC of 4 hr discharge
- P_{minRA} = height of a rectangle where base is 1.5 hours of discharge and area is the battery's available energy (MWh)

Example: 3 MW/12 MWh bi-directional storage resource opting for sustainable (i.e. flat) output:

- P_{maxRA} (height) = 12 MWh (area) / 4h (base) = 3 MW
- P_{minRA} (height) = -12 MWh (area) / 1.5h (base) = -8 MW
- EFC = $P_{maxRA} - P_{minRA}$ = 3 MW - (-8 MW) = **11 MW**



- P_{minRA} is not capped so EFC=11 MW (> 3 times the battery's total capacity)



EFC of Bidirectional Storage cont.


- Continuing with this example, but using a 3 MW/12 MWh bi-directional storage resource opting for upward ramping:

P_{maxRA} remains the same
 P_{minRA} = height of a triangle
(where height = P_{minRA})

$$P_{maxRA} = 12 \text{ MWh (area)} / 4 \text{ h (base)} = 3 \text{ MW}$$

$$P_{minRA} = 2 * [-12 \text{ MWh (area)} / 1.5 \text{ h (base)}] = -16 \text{ MW}$$

$$EFC = P_{maxRA} - P_{minRA} = 3 \text{ MW} - (-16 \text{ MW}) = 19 \text{ MW}$$



- With P_{minRA} remaining uncapped EFC = 19 MW (>6 times the battery's total capacity!)**



Proposed Update to EFC Methodology

- Given that current CPUC methodology assigns a 3 MW battery an EFC of either 11 MW or 19 MW (for sustainable output vs. upward ramping, respectively), staff views this methodology as significantly over-valuing bi-directional storage
 - Suggest capping both P_{minRA} and P_{maxRA} at the QC of a 4-hour dispatch
 - This would equate to an EFC of $2 \times QC$ (encompassing 1.5 hours of both charging and discharging)
 - This methodology is applicable to bi-directional storage resources with both a $P_{demandmin}$ and $P_{supplymin}$ of zero (meaning they can ramp continuously up to and down from 0 MW)



CAISO's EFC Methodology

- CAISO uses the MW output range (accounting for both charge & discharge) that a resource can provide over 3 hours while constantly ramping for EFC value
- Each segment is capped at Pmax, but measured as it ramps (rather than flat output)- thus using a triangle formula
 - As such, using a 3 MW/12 MWh bi-directional storage resource opting for upward ramping:
 - On positive side: Minimum of the QC (3 MW) and $[(12 \text{ MWh (area)} * 2) / 1.5\text{h (base)}]$, which = 16 MW;
 - Minimum = 3 MW
 - On negative side: Maximum of the QC (- 3 MW) and $[(-12 \text{ MWh (area)} * 2) / 1.5\text{h (base)}]$, which = -16 MW;
 - Maximum = -3 MW
 - $\text{EFC} = P_{\text{maxRA}} - P_{\text{minRA}} = 3 \text{ MW} - (-3 \text{ MW}) = 6 \text{ MW}$
- This appears synonymous with staff's proposed simplified EFC methodology of 2 x QC
- However, CAISO proposes to slightly amend this formula going forward



Questions for Discussion

- Do Parties agree with Staff's interpretation of the adopted methodology?
- Are we correct that it overvalues the ramping capability of storage resources?
- Does capping EFC at twice the NQC value make sense?
- How do we best align CPUC and CAISO methodologies?